

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Notice of Monitoring Violation by the ECWSD
July 9, 2020

The City of Eastland/PWS ID 0670002 buys treated water from the Eastland County Water Supply District/PWS ID 0670019 which has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial and chemical contamination. The ECWSD failed to conduct membrane integrity testing one of the three membrane trains at the water treatment plant on June 11, 2020. The failure to conduct the membrane integrity test on June 11, 2020 for Membrane Train 1 is a monitoring violation and we are required to notify you of this violation. If you have any questions regarding this violation, you may contact Ron Duncan at 254-629-8321.

We are taking the following actions to address this issue:

The ECWSD has modified its standard operating procedures to conduct the membrane integrity tests following membrane cleaning.

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). If you want more information about the nature and significance of this violation, you may contact Ron Duncan at 254-629-8321.